VERIFICATION OF CONFORMITY

No.: IN-SH-CP-5627-25521

Applicant: **Shandong Emosin Decorative Products Co., Ltd**

Address: **No.19A-West, Building B19, Baililai Creative and Entrepreneurial Park, Liaocheng Economic and Technological Development Zone, Shandong Province, China**

Manufacturing Plant: **Q/IN-SH-CP-5627-25256**

It has been verified that

Product: **Laminate Flooring**

Main Component: **Laminate**

was submitted by the applicant to the testing of the product in accordance with **ISO 16000-3 & ISO 16000-6 & ISO 16000-9 & ISO 16000-11**.

Based on the submitted sample(s), test was performed according to Decree 2011-321 relative to the labeling of construction products, floor or wall coverings and paints and lacquers concerning their emission of volatile pollutants, sample is A+ class on basis of the test report of **CANPC25025919001**.



This verification is valid from **08 December 2025** until **07 December 2028** and remains valid as long as the manufacturing conditions in the plant and the factory production control itself are not modified significantly.

Issue 1. This verification was first issued on **08 December 2025**

Authorised by

Scan to see the report

IN-SH-CP-5627-25521
Verification:
check.sgsonline.com.cn

Lisa Liang
Manager
Industries Service - CP Certification

SGS-CSTC Standards Technical Services Co., Ltd.
16F Century Yuhui Mansion, No.73 Fucheng Road, Haidian District, Beijing, China 100142
email CN.CONSTProdcert@sgs.com **website** www.sgs.com

Disclaimer: Neither SGS-CSTC, any of it affiliated SGS sister organizations nor the SGS Group can be held responsibly for conformity or non-conformity of the actual product with the contents of the Technical File. Copyright of this verification is owned by SGS-CSTC IND Services and may not be reproduced other than in full.

VERIFICATION OF CONFORMITY

No.: IN-SH-CP-5627-25521

··continued··

Results of examinations are as following:

Compound Name	CAS NO.	7th day Result μg/m³	Classes requirements			
			C	B	A	A+
Formaldehyde	50-00-0	2.2	> 120	< 120	< 60	< 10
Acetaldehyde	75-07-0	3.1	> 400	< 400	< 300	< 200
Toluene	108-88-3	Not detected	> 600	< 600	< 450	< 300
Tetrachloroethene	127-18-4	Not detected	> 500	< 500	< 350	< 250
Xylene	1330-20-7	Not detected	> 400	< 400	< 300	< 200
1,2,4-Trimethylbenzene	95-63-6	Not detected	> 2000	< 2000	< 1500	< 1000
1,4-Dichlorobenzene	106-46-7	Not detected	> 120	< 120	< 90	< 60
Ethylbenzene	100-41-4	Not detected	> 1500	< 1500	< 1000	< 750
Ethylene Glycol Monobutylether (Butoxyethanol)	111-76-2	Not detected	> 2000	< 2000	< 1500	< 1000
Styrene	100-42-5	Not detected	> 500	< 500	< 350	< 250
TVOC	-	Not detected	> 2000	< 2000	< 1500	< 1000

Conclusion: Based on the submitted sample(s), test was performed according to Decree 2011-321 relative to the labeling of construction products, floor or wall coverings and paints and lacquers concerning their emission of volatile pollutants, sample is A+ class.

Statement: Unless otherwise stated the results shown in this verification refer only to the sample(s) tested. The manufacturer is obligated to guarantee stability of product performance.

Issue 1. This verification was first issued on **08 December 2025**

Authorised by

Lisa Liang

Manager

Industries Service - CP Certification

Disclaimer: Neither SGS-CSTC, any of it affiliated SGS sister organizations nor the SGS Group can be held responsibly for conformity or non-conformity of the actual product with the contents of the Technical File. Copyright of this verification is owned by SGS-CSTC IND Services and may not be reproduced other than in full.